January 30, 2015

SIGN AND RETURN INSIDE YOUR SEALED BID

ADDENDUM 3

ITB 45-0170 / Media Services AV Equipment and Installation / Addendum 3

ITB 45-0170 is hereby amended as follows:

Q&A

Q1/A1 are on prior addendum

- **Q2**: The functional diagram for the training room on drawing AV-03, detail 1 calls for a DE Embedder. Please provide desired manufacturer and model number for this unit.
- **A2**: Artlona model AT-HD570
- Q3: Section 27 41 16, part 2, 2.3, products for the Training Room, the model number for these speakers is not a valid number. Please provide correct model number speakers we should include in bid.
- A3: Use Atlas Sound model S162TUSA that comes complete with tile bridge speaker, baffle and backbox.
- **Q4**: Please confirm the laptop shown at the training room is OFE. If not, please provide required specifications.
- **A4:** Laptop is the property of the University or the instructor using the room.
- Q5: Section 27 41 16, part 2, 2.2, products for all rooms show SP Controls Catlinc HDMI extender (TX/RX Pair), but product lists for other rooms call for Kramer HDMI extender. Please confirm which ones we are to include in bid.
- **A5**: The Catlinx is for VGA and the Atlona is for HDMI and each is to be used where the respective signal type is shown. In the training room, for example, both are to be provided.

Q6 :	Section 27 41 16, part 2, 2.3, products for the Training Room call for a total 4ea. "Marking Video Monitor" units. Two are shown under hardware items and two under video devices. This appears to be a typo since the functional diagram only shows one connected to the OFE PC and the functional description under part 1.2, B, 11 indicates that the digital marking display is connected to the OFE computer.
A6:	The spec currently lists two (2) Smarttech Podium 500 units in the training room and two (2) in the Recording room. There needs to be one in the training room and 2 in the recording room.
Bidder acknowledgement SIGN AND RETURN INSIDE YOUR SEALED BID	
 Date	